

**SEDGWICK COUNTY FIRE DISTRICT #1**  
**ITEMS REQUIRING BOCC APPROVAL**  
**June 11, 2020**  
**(1 ITEM)**

**1. FIRE ATTACK AND SUPPLY HOSE -- FIRE DISTRICT #1**

**FUNDING -- FIRE DISTRICT #1**

(Request sent to 35 vendors)

RFB #20-0033 Contract

Fire Hose Length / Coupling	Color	Estimated Initial Purchase	Casco Industries, Inc.		Danko Emergency Equipment		Emergency Fire Equipment, Inc.*	
1. 100 Foot Sections - 5 in.; Ea.	Yellow	30	\$597.75	\$17,932.50	\$570.59	\$17,117.70	\$906.67	\$27,200.10
2. 50 Foot Sections - 1.75 in.; 180 GPM at 50 psi; Ea.	Red	95	<b>\$182.65</b>	<b>\$17,351.75</b>	\$232.35	\$22,073.25	\$148.00	\$14,060.00
3. 50 Foot Sections - 1.75 in.; Ea.	Yellow	46	<b>\$182.65</b>	<b>\$8,401.90</b>	\$232.35	\$10,688.10	\$177.13	\$8,147.98
4. 50 Foot Sections - 2.5 in.; 300 GPM at 50 psi; Ea.	Orange	150	\$188.82	\$28,323.00	\$272.94	\$40,941.00	\$214.00	\$32,100.00
Shipping			<b>Included for orders over \$5,000.00</b>					
Acknowledge Addendum			Y		Y		Y	
Fire Hose Length / Coupling	Color	Estimated Initial Purchase	Ed M. Feld Equipment Co., Inc. dba Feld Fire Option 1		Ed M. Feld Equipment Co., Inc. dba Feld Fire Equipment Option 2**		Municipal Emergency Services, Inc.	
1. 100 Foot Sections - 5 in.; Ea.	Yellow	30	\$579.50	\$17,385.00	\$563.95	\$16,918.50	<b>\$510.00</b>	<b>\$15,300.00</b>
2. 50 Foot Sections - 1.75 in.; 180 GPM at 50 psi; Ea.	Red	95	\$234.00	\$22,230.00	\$120.98	\$11,493.10	\$205.00	\$19,475.00
3. 50 Foot Sections - 1.75 in.; Ea.	Yellow	46	\$234.00	\$10,764.00	\$120.98	\$5,565.08	\$205.00	\$9,430.00
4. 50 Foot Sections - 2.5 in.; 300 GPM at 50 psi; Ea.	Orange	150	\$278.00	\$41,700.00	\$167.96	\$25,194.00	\$280.00	\$42,000.00
Acknowledge Addendum			Y		Y		Y	
Fire Hose Length / Coupling	Color	Estimated Initial Purchase	Weis Fire and Safety Equipment, LLC					
1. 100 Foot Sections - 5 in.; Ea.	Yellow	30	\$565.91			\$16,977.30		
2. 50 Foot Sections - 1.75 in.; 180 GPM at 50 psi; Ea.	Red	95	\$235.23			\$22,346.85		
3. 50 Foot Sections - 1.75 in.; Ea.	Yellow	46	\$235.23			\$10,820.58		
4. 50 Foot Sections - 2.5 in.; 300 GPM at 50 psi; Ea.	Orange	150	<b>\$165.91</b>			<b>\$24,886.50</b>		
Acknowledge Addendum			Y					
No Bid			Conrad Fire Equipment	John M. Ellsworth Company, Inc.	Mid-Continent Safety, LLC	Vallen		

On the recommendation of Josh Lauber, on behalf of Sedgwick County Fire District #1 (SCFD #1), Linda Kizzire moved to **accept the low bids meeting specifications for item 1 from Municipal Emergency Services, Inc., for items 2 and 3 from Casco Industries, Inc., and item 4 from Weis Fire and Safety Equipment, LLC and establish contract pricing as listed above for two (2) years with three (3) one (1) year options to renew.** Tim Myers seconded the motion. The motion passed unanimously.

This contract is to assist SCFD #1 in replacing water supply and fire attack hose over the next five (5) years. SCFD #1 have set standard fire attack hose and supply hose packages on our Engines and Quints, with tested water flows for interior fire attack, aligning the district with the current standards per the National Fire Protection Association (NFPA). The contract will assist SCFD #1 with replacement over the allotted period, saving time and money for the district in repairs and fire hose failures. Over the next five years the district expects to spend between \$47,000 to \$72,500 per year on hose replacement. These vendors have worked with the district previously and have met the district's specifications with no exceptions.

Notes:

\*Emergency Fire Equipment, Inc. was disqualified due to suggested solution/product (Key Item#DP1700-800) not meeting the bend/kink requirement outlined in bid specifications. The hose must be resistant to kinking and be flexible at 50 PSI with a bend radius of no more than 17 inches without kinking (spec item 15 of 1.75 Fire Attack Hose).

\*\*Ed M. Feld Equipment Co., Inc. dba Feld Fire Equipment Opt. 2 was disqualified due to the product being manufactured outside the United States (Spain and Argentina).