



*Sedgwick County...  
working for you*

SEDGWICK COUNTY, KANSAS  
COMMUNICATIONS

# NEWS

CONTACT: SEDGWICK COUNTY COMMUNICATIONS 316-660-9370 FAX: 316-383-7509

**FOR IMMEDIATE RELEASE**

July 13, 2009

**Contact:**

Amanda Matthews  
Kristi Zukovich  
316-660-9370

**SMOKE ALARM RECALL**

(Sedgwick County, Kansas) – The U.S. Consumer Product Safety Commission has announced a voluntary recall of the Kidde Dual Sensor Smoke Alarm – Model P12000. An electrostatic discharge can damage the unit, causing it not to warn consumers of a fire.

Only date codes August 1, 2008 through May 4, 2009 are included in this recall. The model number and date code are on the back of the smoke alarm.

The Sedgwick County Fire District #1 encourages consumers to stop using recalled products immediately. To receive a free replacement smoke alarm, consumers should contact Kidde at (877) 524-2086 or visit the firm's Web site at [www.kidde.com](http://www.kidde.com).

“Smoke detectors should be tested monthly and their batteries replaced annually,” said Sedgwick County Fire Marshall Tim Millspaugh. “This will help ensure the equipment works properly when it's needed.”

- end -