

ADDENDUM #1



MKEC ENGINEERING CONSULTANTS, INC.
411 North Webb Road
Wichita, KS 67206
316-684-9600 FAX 316-618-8083

TO: All Bidders furnishing labor and materials

FROM: Richard Bartlett, P.E.

REFERENCE: Data Center Air Conditioning Replacement for
Historic Sedgwick County Courthouse

DATE: October 7, 2003

MESSAGE: This addendum is hereby made part of the Contract Documents to the same extent as though it were originally included herein. All contractors, subcontractors, and suppliers are advised of the following:

Item #1 Specification Section 15734-Computer Room Air Conditioning Units
IPAC, Inc. and Compu-Aire, Inc. are not acceptable manufacturers.
Liebert, Inc, Data-Aire, Inc, and Canatal are acceptable manufacturers.