

**SEDGWICK COUNTY HISTORIC COURTHOUSE
FOUR CORNER TOWERS RE-ROOF WORK
510 NORTH MAIN
WICHITA, KANSAS
PROJECT #04-0073**

ADDENDUM NO. 3

October 13, 2004

NOTICE TO ALL BIDDERS FOR THE

Sedgwick County Historic Courthouse
Four Corner Towers Re-roof Work
510 North Main
Wichita, Kansas

You are instructed to read and to note the following described changes, corrections, clarifications, omissions, deletions, additions, approvals and statements pertinent to the Contract Bid and Construction Documents.

The Addendum No. 3 is a part of the Contract Bid and Construction Documents and shall govern performance of the work.

ARTICLE 1-1, Specification Section 07322

- a. Revise the following Specification Section 07322 – Synthetic Roofing Tiles section as indicated in Addendum No. 1:
 1. Revise 2.1-B to read as follows: Installed over a minimum of ½ inch treated plywood **over Hunter Panel nail base of minimum thickness required to allow full anchorage of nails without contacting the concrete deck** over existing concrete roof deck with manufacturer recommended drilled anchor system.