

**SEDGWICK COUNTY MAIN COURTHOUSE BUS DUCT REPLACEMENT
525 NORTH MAIN
WICHITA, KANSAS
PROJECT #04-0087**

ADDENDUM NO. 3

December 23, 2004

NOTICE TO ALL BIDDERS FOR THE

Sedgwick County Main Courthouse Bus Duct Replacement
525 North Main
Wichita, Kansas

You are instructed to read and to note the following described changes, corrections, clarifications, omissions, deletions, additions, approvals and statements pertinent to the Contract Bid and Construction Documents.

The Addendum No. 3 is a part of the Contract Bid and Construction Documents and shall govern performance of the work.

ARTICLE 1-1, Additional Bus Duct Information

- a. **The busway shall have an internal ground bar with a minimum capacity of 50% in lieu of the integral ground as stated in the original specifications.**