



**SEDGWICK COUNTY, KANSAS**

***DIVISION OF FINANCE***

**Purchasing Department**

604 N. Main, Suite F

Wichita, KS 67203

Telephone (316) 660-7255

Fax (316) 383-7055

**REQUEST FOR BID  
#06-0038  
JUVENILE COURT/DISTRICT ATTORNEY FACILITY  
ADDENDUM #4**

November 28, 2006

Please review the following clarifications and additions to the specifications for this project. This addendum and all of the information contained herein is to be considered an official part of contract for this project.

**You must acknowledge receipt of this addendum on your response form.**

**SECTION 15684 - ROTARY WATER CHILLERS:**

Paragraph 2.2, COMPRESSOR AND MOTOR: Add the following:

Chillers utilizing scroll compressors will be acceptable as an alternative to the rotary compressors. A minimum of 4 scroll compressors and 2 independent refrigerant circuits will be required. A minimum of 4 equal capacity steps are required, with 25 percent minimum capacity.

**DRAWINGS**

**SHEETS CI101 AND CI501 – SITE IMPROVEMENTS AND DETAILS:**

The north/south 8-foot-high metal fence indicated along the west property line (approximately 540 lineal feet) shall be deleted from this scope of work. This fence as specified in SECTION 02825 – METAL FENCE is no longer available from the specified manufacturer, and apparently no equal is available. A replacement fence type will be determined at a later date, after the contract is awarded.

**SHEET A102 – AREA ‘A’ ARCHITECTURAL FLOOR PLAN:**

A 3-foot clear minimum dimension shall be maintained in Passageway B121/B132, at the column location near the northeast corner of Conference B119.

---

Emily C. Dudley, A.P.P.  
Purchasing Agent