



SEDGWICK COUNTY, KANSAS
DIVISION OF FINANCE
PURCHASING DEPARTMENT

525 N. Main, Suite 823 ~ Wichita, KS 67203
Phone: 316 660-7255 Fax: 316 383-7055

<http://sedgwickcountv.org/finance/purchasing.asp>

Request for Bid
#13-0030
Pre-Cast Reinforced Concrete Box and End Sections
Addendum #1

March 12, 2013

The following is to ensure that vendors have complete information prior to submitting a proposal. Here is a clarification regarding the bid for Pre-Cast Reinforced Concrete Box and End Sections.

Questions and/or statements of clarification are in bold font, answers to specific questions are italicized.

A new table has been provided for the bid response form. Several items have been deleted from the original table. Please provide responses utilizing the table provided in this addendum.

Firms interested in submitting a bid, must respond with complete information and all supplementary materials and **deliver on or before 1:45 p.m. (CDT), Tuesday, March 19, 2013.** Late bids will not be accepted and will not receive consideration for final award.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID RESPONSE PAGE.

Joe Thomas, C.P.M.
Acting Purchasing Director

Pre-Cast Reinforced Concrete Box and End Sections

Quantity	Item Description	Unit Price	Total Price
Standard RCB Pre-cast Sections			
5 each	12' x 5' x 6'		
Pre-cast RCB Section - Hubguard			
2 each	12' x 5'		
4 each	10' x 5'		
4 each	8' x 4'		
Straight Wing Miltred End Sections			
2 each	12' x 5'		
Joint Couplers (galvanized threaded anchors)			
8 each			
Grand Total			

Items listed above will be FOB Prepaid and Delivered, with delivery to various locations in Sedgwick County.

Delivery timeline: _____

Specifications

Each precast reinforced concrete box cell shall meet the material specifications of the latest revision of Section 735 of the 2007 Edition of the Kansas Department of Transportation Standard Specifications for State Road and Bridge Construction (hereinafter called "Standard Specifications"). Box culvert analysis and reinforcing design (Boxcar, Version 2.0 or later) Software developed by the Federal Highway Administration in cooperation with the American Concrete Pipe Association is the preferred method for the design of precast box culverts for Sedgwick County.

The successful bidder will be required to submit their design reports for each culvert, along with the shop drawings required under the aforementioned Section 735, prior to fabrication.

The rubber gasket and geotextile fabric shall meet the requirements of Subsection 735.28 of the original version of the Standard Specifications.