



**SEDGWICK COUNTY, KANSAS**  
***DIVISION OF FINANCE***  
**Purchasing Department**  
525 N. Main, Suite 823 ~ Wichita, KS 67203

Phone: 316 660-7255 Fax: 316 383-7055

<http://sedgwickcounty.org/finance/purchasing.asp>

**REQUEST FOR BID**  
**#13-0049**  
**SLIP-IN PUMP AND TANK UNITS**

April 16, 2013

SEDGWICK County, Kansas (hereafter referred to as County) will accept bids to select a vendor to provide two (2) slip-in pump and tank units for Sedgwick County Fire Department. It is anticipated that an official contract or purchase order will be issued after Board of County Commission approval of the recommended bid. It should be noted, however, that the County cannot guarantee the purchase of the product described herein.

Carefully review this Request for Bid. It provides specific technical information necessary to aid participating firms in formulating a thorough response. Should firms elect to participate, one (1) complete original and one (1) electronic copy (disc or flash drive) of the entire document must be completed and returned with any supporting data in a sealed envelope/package, marked on the lower left-hand corner with the firm name and address, bid number, bid opening date, and returned to the Sedgwick County Purchasing Department, 525 N. Main, Suite 823, Wichita, KS 67203, no later than **1:45 p.m., CDT, Tuesday May 7, 2013**. Late or incomplete responses will not be accepted and will not receive consideration for final award. The time stamp clock in the Purchasing Department will determine the time of receipt.

---

Kimberly Evans  
Purchasing Agent

**1. MINIMUM MANDATORY REQUIREMENTS AND SPECIFICATIONS**

- A. The following specifications are for the procurement of two (2) slip-in pump and tank units for Fleet Management to be used by the Fire Department.
- B. Manufacturer’s standard equipment presumed to be included unless otherwise specified.
- C. All items bid are to be factory installed unless authorized by Sedgwick County Fleet Management.
- D. Delivery of equipment must be Sedgwick County Fire Department Maintenance facility located at 1021 W. Stilwell, Wichita, KS.
- E. Maintenance manuals to be invoiced separately.
- F. Provide all warranty information.

**Equipment shall meet or exceed the following: any additions, deletions, or variations from the following specifications must be noted.**

<b>A. Pump, Engine, and Plumbing.</b>	<b>Comments</b>												
1. Pump: Hale, Model HPXB100-B18, Unit delivered will be equipped with electric start.													
2. Engine: Briggs & Stratton “Vanguard” Model 350400 Series with 18 Horsepower.													
3. Pump to be centrifugal design, minimum capacities to be: <table style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <tr> <td style="padding: 0 10px;"><u>GPM</u></td> <td style="padding: 0 10px;"><u>At</u></td> <td style="padding: 0 10px;"><u>PSI</u></td> </tr> <tr> <td style="padding: 0 10px;">15</td> <td style="padding: 0 10px;"></td> <td style="padding: 0 10px;">280</td> </tr> <tr> <td style="padding: 0 10px;">100</td> <td style="padding: 0 10px;"></td> <td style="padding: 0 10px;">150</td> </tr> <tr> <td style="padding: 0 10px;">150</td> <td style="padding: 0 10px;"></td> <td style="padding: 0 10px;">50</td> </tr> </table>	<u>GPM</u>	<u>At</u>	<u>PSI</u>	15		280	100		150	150		50	
<u>GPM</u>	<u>At</u>	<u>PSI</u>											
15		280											
100		150											
150		50											
4. Impeller to be bronze double hubbed for hydraulic balance.													
5. Wear rings to be bronze replaceable type.													
6. Shaft seal to spring load mechanical.													
7. Spark arrestor and exhaust venture primer to enable drafting from tank or other water supply.													
8. Pump and engine to be located at floor level of skid to completely eliminate pump priming problems when pumping from booster tank. Pump and engine and fuel tank will be mounted on skid floater.													
9. Heavy duty piping and fittings used throughout the system. All plumbing will be designed to prevent electrolysis.													
10. Brass drains to fully drain pump, manifold & plumbing. Pump manifold design will allow for complete draining of all pump valves, hoses, and plumbing due to extended periods of outside storage due to Drill cycles or other occasions where Apparatus will be un-attended in inclement weather.													
11. Pump engine starter to be prewired with plug-in connectors to enable hook-up to vehicle battery and charging system.													
12. Pump engine will have an oil drain line plumbed to the front of the control panel area, floor level, to allow for easy access for draining oil. Drain line will have a valve accessible from the pump control panel area (at floor level). The Pump/Engine shall be isolation mounted onto a cross linked polyethylene platform which also serves as a 3 gallon gas tank													
<b>B. Required Operating Valves/Controls/Fittings:</b>													
<p>General Requirement: All valves required/specified and supplied/installed with slip-in pump units will be full flow, quarter turn, ball valves. All control valve handles to be legibly identified for ease of operation. All suction and discharge connections including caps will be high quality and chrome plated with chains attached where applicable.</p> <p><b>Note: All Intake and discharge valves will be an 8800 series valve manufactured by Akron Brass.</b></p>													
1. One Each, 2-1/2” inlet with a 2-1/2” brass valve with cap. Thread to be 2-1/2” NSTF. Valve control will be at the valve and accessible from the rear of the													

truck (near but not on the pump panel). A check valve will be installed at the tank location to prevent back filling the tank from a fire hydrant. This action is intended to reduce the chances of damage to the internal plumbing inside the tank.	
2. One Each, 2-1/2" tank to pump valve. Valve control will be at the valve and accessible from the rear of the truck (but not on the pump panel).	
3. One Each, 1.5" minimum brass quarter turn ball valve with control at the pump control panel, shall be provided for recirculating water to prevent pump overheating or winter freeze-up. A 1-1/2" check valve will be installed at the tank connection to prevent water from draining out of the tank into the plumbing to reduce the chances of freeze-up. The dis-charge hose from the valve going to the tank will be of 1-1/2" I.D. hose.	
4. One Each, 1.5" brass, quarter turn ball valve for the booster line with control at the pump panel. The dis-charge hose from the valve going to the booster reel will be of 1.5" I.D. hose.	
5. One each, 1.5" brass, quarter turn ball valve with control at the pump panel, shall be provided for supplying a 1" forestry hose. Forestry hose connection shall be 1" MNST and accessible at the rear of the truck (but not on the pump panel).	
6. One each, 1.5" pre-connect with Chickson swivel and ¼ turn full flow ball valve with control at the pump panel. The dis-charge hose from the valve going to the pre-connect swivel will be 1-1/2" I.D. hose.	
7. One each, 1" brass quarter turn ball valve with control at the pump panel shall be provided for supplying a garden hose fitting. Garden hose fitting shall be accessible at the rear of the truck (but not on the pump panel).	
<b><u>C. Pump/Valve Operating Control Panel</u></b>	
1. Control panel will have a minimum dimension of twenty (20) inches in width x (20) in height. (No exceptions to minimum pump panel size.) Pump panel will be solid mounted to the rear of the skid unit and will support rapid access to all controls for operating from the rear of the truck. Panel will be constructed of Aluminum or Stainless Steel.	
2. Control panel will be designed to provide easy access to operator while standing behind truck with unit installed	
<b><u>The following controls, at a minimum, will be located on the above pump control panel:</u></b>	
1. Lighted pump-engine control panel prewired for connection to the vehicle battery	
2. Start-stop switch for pump engine.	
3. Hand throttle control will be vernier style (no exceptions).	
4. Choke control.	
5. Low Oil Pressure indicating light	
6. 2.5" inch minimum diameter, lighted discharge gauge, temperature rated to 30 degrees below zero, 0-400 psi.	

7. Valves/Controls for the following functions: 1) garden hose; 2) recirculating/refill valve; 3) Booster hose; 4) forestry hose; 5) crosslay hose. All will have proper identification labels attached.	
8. Primer Control	
9. Class 1 Intelli-tank 4 water level gauge	
<b>D. Water/Booster Tank</b>	
1. Tank will be a "UPF POLY-TANK". <i>Defender 3 Series</i>	
2. Tank capacity will be 300 Gallons with 8 gallon foam cell.	
3. Tank will be designed to keep the height at the lowest profile practical/possible. This requirement is to keep the weight of the unit as low as possible in the truck for stability reasons.	
4. Tank to be baffled for approximately 40 to 63 gal. Compartments. Tank to be designed to prevent swirling, cavitation, and to provide a suction sump floor.	
5. 8" fill tower, 3" overflow / vent, with cap.	
6. Tank will be constructed of 1/2" thick textured polypropylene sheet stock with AccTuf resin. The material shall be of a certified, high quality, non-corrosive stress relieved thermoplastic, and shall be black in color.	
7. Tank outlet to be a minimum of 2-1/2".	
8. Tank to have fill indicator panel made of translucent material.	
<b>E. Hose Beds</b>	
1. Tank cover to include an aluminum hose bed to support 200 ft. of 1.75" double jacket hose. Aluminum shall be a minimum of 1/4" thick and full seam welding as where required. Exact interior dimensions of the hose bed are not known at this time, but will be approximately 8" in width x 54" in length x 8" in height.	
2. Owner's representative will approve exact positioning of this hose bed.	
3. Hose bed will have a hinged (piano style) cover installed on top. The hinge will run the entire length of the hose bed. Hinge will be made of Stainless Steel.	
4. Hose bed to be plumbed with a 1.5" chickson swivel and control shall be at the pump control panel.	

<b>F. <u>Booster Reel:</u></b>	
1. Hanney, Model SBEP-F 38-23-24 <b>(No Exceptions)</b> , electric rewind hose reel with two hundred fifty feet capacity for 1” booster hose. Control valve for booster line will be a full flow, ¼ turn ball valve, located at the pump control panel.	
2. Two hundred (200) feet of 1”, 800 psi BOSTON MFD hose coupled each 100 feet with BARWAY Couplings to be furnished (no exceptions to brand of hose or couplings).	
3. 2 hose guides to protect hose when pulling off right or left side of the vehicle. One located on the booster reel and one located on the pump panel.	
4. Rewind button for booster reel will be located at the pump control panel.	
5. Booster reel will be mounted such that the hose can be removed from the rear of the truck.	
6. Booster reel operation will be controlled by 1.5” valve at pump control panel.	
<b>G. Option 1</b>	
Engine HPX100-LD26 Pump unit IPO HPXB100-B18	
<b>Option 2</b>	
Engine HPXB200-B18 Pump unit IPO HPXB100-B18	
<b>Option 3</b>	
Foam System	
The skid unit shall be equipped with an Foam Pro 1601-1.5M fully electronic, variable speed direct injection, and discharge side foam proportioning system. The system shall be capable of handling Class A foam concentrate. The foam system shall be based on direct measurement of water flows and remain consistent within the specified flows and pressures. System must be capable of delivering accuracy to within 3% of calibrated settings over the advertised operation range when installed to factory standards. The system shall be equipped with a control module suitable for installation on the pump panel. Incorporated within the motor driver shall be a microprocessor that receives input from the system flow-meter, while also monitoring foam concentrate pump output, comparing values to ensure proper that the operator preset proportional amount of foam is injected into the discharge side of the pump. A paddlewheel type flow-meter shall be installed in the discharge system specified to be foam capable.	
<b>H. Dimensions, Skid Unit &amp; Miscellaneous Other General Requirements:</b>	
1. Engine, Plumbing and all components will be painted Red (or combination Red and Black) with high quality finish.	
2. Owner desires to keep tank profile as low as practical and within the limitations of the water tank capacity requirements and the truck beds dimensions. The overall design of this slip-in pump unit must be capable of	

being mounted within Owner supplied KNAPHEIDE Model 6108D54J utility bed mounted on a Ford 550 Crew-Cab Series Chassis. Approximate dimensions of said utility bed are: Width 49 in. Length 108 in., Units shall also be designed to accommodate wheel well dimensions. <i>Bidders assume ALL RESPONSIBILITY for verifying all information related to utility bed dimensions and conditions.</i>	
3. <i>Note: SUCCESSFUL BIDDER WILL VERIFY ALL DIMENSIONS OF PROPOSED SKID MOUNTED PUMP UNIT FOR OWNER APPROVAL PRIOR TO FABRICATING THE SAME.</i>	
4. Pump panel to be painted black. Pump may be painted red or some combination of Red and Black depending on normal practice. Verify with Owner.	
<b>I. Warranty Requirements:</b>	
1. All components EXCEPT tank unit supplied will have a full warranty to cover 100% of all components including required parts and labor for a period of one year.	
2. Water Tank will have a LIFETIME warranty.	
<b>J. Exceptions:</b>	
Bidders will identify all exceptions requested on a separate page titled "EXCEPTIONS TO SPECIFICATIONS" which will be submitted with their bid quote. Bidders will make reference to the subject and paragraph exception pertains to. Exceptions will be fully supported with engineering data, photos, illustrations, and all other information needed for owner's representative to make a full and complete evaluation of exception requested.	
<b>K. Dimensions, Skid Unit &amp; Miscellaneous Other General Requirements:</b>	
5. Engine, Plumbing and all components will be painted Red (or combination Red and Black) with high quality finish.	

## **2. QUESTIONS AND CLARIFICATIONS**

All requests for clarifications of the RFB process and document content should be directed to Kim Evans at [kjevans@sedgwick.gov](mailto:kjevans@sedgwick.gov) and Brian Richey [brichey@sedgwick.gov](mailto:brichey@sedgwick.gov). All questions must be submitted in writing by 5:00 p.m., April 22, 2013. Answers will be provided in written form as an addendum and will be posted on the County website at [www.sedgwickcounty.org/Finance/Purchasing.asp](http://www.sedgwickcounty.org/Finance/Purchasing.asp) by 5:00 p.m., April 25, 2013. **Vendors are responsible for checking the web site and acknowledging any addendums on their response form.**

## **3. TENTATIVE TIMELINE**

The following dates are provided for information purposes and are subject to change without notice. Contact the Purchasing Department at (316) 660-7255 to confirm any and all dates.

Distribution of Request for Bid to interested parties	April 16, 2013
Clarification, Information and Questions submitted in writing by 5:00 p.m. CDT	April 22, 2013
Addendum Issued	April 25, 2013
Sealed bids due before 1:45pm CDT	May 7, 2013
Evaluation Period	May 8-29, 2013
Board of Bids and Contracts Recommendation	May 30, 2013
Board of County Commission Award	June 5, 2013

#### **4. REQUEST FOR BID CONDITIONS**

In submitting a response to this Request for Bid, vendors hereby understand the following:

1. Pricing offered in the bid document will be provided to other local governments and governments whom Sedgwick County regularly enters into cooperative agreements.
2. Sedgwick County reserves the right to reject any and/or all bids and responses to these and/or related documents, to accept any item(s) in the bids, to waive any irregularity in the bids, and further if determined to be non-responsive in any form, or if determined to be in the best interest of Sedgwick County.
3. Alternate bids (two or more bids submitted) will be considered for an award. Sedgwick County reserves the right to make the final determination of actual equivalency or suitability of such bids with respect to requirements outlined herein. The bids submitted, and any further information acquired through interviews, will become and is to be considered a part of the final completed contract. If there is any variance or conflict, the bid specifications will control.
4. Bidders MUST return, completed copies of the entire document to the Sedgwick County Purchasing Department, 525 North Main, 8<sup>th</sup> Floor, Suite 823, Wichita, KS 67203, on or before the date and time specified. Bids must be sealed in an envelope and marked with the firm name and address, bid number, bid opening date, and bid opening time. The time clock stamp, located in the Sedgwick County Purchasing Department will determine the time of receipt.
5. Bids submitted may not be withdrawn for a period of 60 days immediately following the opening of this Request for Bid. Prices MUST be free of federal, state, and local taxes unless otherwise imposed by a governmental body, and applicable to the material on the bid.
6. Sedgwick County interprets the term "Lowest Responsible and Best Bidder" as requiring Sedgwick County to: (a) choose between the kinds of materials, goods, wares, or services subject to the bid, and (b) determine which bid is most suitable for its intended use or purpose. Sedgwick County can consider, among other factors, such things as the availability of service(s), part(s) material(s) and/or supply(s), warranty, maintenance, freight costs, performance of product and labor cost of items upon which bids are received.
7. All requested information must be supplied. If bidders cannot respond to any part of this request, bidders should state the reason they cannot respond and note an exception. Bidders may provide supplemental information to assist Sedgwick County in analyzing its bid.
8. If the bidder refuses or fails to make deliveries of the materials within the times specified on the face of the Request for Bid or purchase order, Sedgwick County may, by written notice, terminate the contract or purchase order.
9. The bidder will certify and warrant that goods, personal property, chattels, and equipment sold and delivered are free and clear of any and all liens, or claims of liens, for materials or services arising under, and by virtue of the provisions of K.S.A. Sections 58-201, et seq., and any other lien, right, or claim of any nature or kind whatsoever.
10. The successful bidder will hold and save Sedgwick County, and its officers, agents, servants/employees harmless from liability of any patented, or unpatented invention, process, article, or appliance manufactured, or used in the performance of the contract, including its use by Sedgwick County. Vendors working on county property or on behalf of County will be required to carry minimum insurance listed in bid document.
11. All items furnished, if applicable, must be the best of their respective kinds, and will be free from defects in material and workmanship. Items will be subject to County inspection and approval at any time within 30 days after delivery. If a substitution is made, it will be the decision of a Sedgwick County representative to determine if it is of equal quality. Items furnished must be manufactured in compliance with all existing legal or governmental directives.
12. Unless specified otherwise, all items bid are to be as a minimum but not necessarily limited to: new, current model year, and untitled prior to shipping and/or installation.
13. Sedgwick County is desirous of allowing as many Kansas vendors as possible the opportunity to participate including minority men and women-owned businesses, and small businesses in the roles of providing goods and services to Sedgwick County. If your company does not fall into any of these categories, your efforts to contract with vendors who do fall into these categories are appreciated. Construction projects utilizing subcontractors requires a subcontracting worksheet. Contact purchasing department for details.
14. Contracts entered into on the basis of submitted bids are revocable if contrary to law.
15. County reserves the right to enter into agreements subject to the provisions of the Cash Basis Law (K.S.A. 10-1112 and 10-1113), the Budget Law (K.S.A. 79-2935). Agreements shall be construed and interpreted so as to ensure that the County shall at all times stay in conformity with such laws, and as a condition of agreements the County reserves the right to unilaterally sever, modify, or terminate agreements at any time if, in the opinion of its legal counsel, the Agreement may be deemed to violate the terms of such law.

16. The Bidder agrees to comply with K.S.A. 44-1030.
  - a. The contractor shall observe the provisions of the Kansas act against discrimination and shall not discriminate against any person in the performance of work under the present contract because of race, religion, color, sex, disability, national origin, or ancestry;
  - b. In all solicitations or advertisements for employees, the contractor shall include the phrase, "equal opportunity employer," or a similar phrase to be approved by the commission;
  - c. If the contractor fails to comply with the manner in which the contractor reports to the commission in accordance with the provisions of K.S.A. 44-1031 and amendments thereto, the contractor shall be deemed to have breached the present contract and it may be canceled, terminated or suspended, in whole or in part, by the contracting agency;
  - d. If the contractor is found guilty of a violation of the Kansas act against discrimination under a decision or order of the commission which has become final, the contractor shall be deemed to have breached the present contract and it may be canceled, terminated or suspended, in whole or in part, by the contracting agency; and
  - e. The contractor shall include the provisions of subsections (a) through (d) in every subcontract or purchase order so that such provisions will be binding upon such subcontractor or vendor.
17. All project participants, consultants, engineers, contractors and subcontractors, must comply with all applicable Federal, State and County laws pertaining to contracts entered into by governmental agencies. All participants must comply with the Americans with Disabilities Act (ADA), including the 2008 ADA Amendments Act, and 2010 ADA Standards for Accessible Design.
18. Contractors/subcontractors performing new construction, maintenance, alterations, or additions to Sedgwick County buildings or facilities must comply with building guidelines/codes, and the 2010 ADA Standards for Accessible Design. Any violation of the provisions of the ADA or 504, or specification deficiencies, should be reported to the county's ADA coordinator. Failure to notify the county's ADA coordinator for remedy may be considered a breach of contract and may be grounds for cancellation, termination for suspension, in whole or in any part of the contract. All construction plans will have the county's ADA coordinator approval prior to beginning any work.
19. Contractors/vendors providing services to the public on behalf of Sedgwick County will agree that all personnel in their employment that have direct contact with the public will attend ADA Awareness and Sensitivity training provided by Sedgwick County or the Independent Living Resource Center. Training should be coordinated through the county's ADA coordinator, (316) 660-7052 and evidence of training shall be provided to the county's ADA coordinator. Any violations of the provisions of ADA or section 504, will be deemed a breach of contract and be subject to termination of contract.
20. The successful bidder may have access to private or confidential data maintained by the County to the extent necessary to carry out its responsibilities of the contract. Contractor shall be responsible for compliance with the privacy provision of the Health Insurance Portability and Accountability Act (HIPAA) and shall comply with all other HIPAA provisions and regulations applicable. If the successful bidder is a business associate as that term is defined under HIPAA, the contract shall include the County's standard business associate addendum. A copy of that standard addendum is available on request.
21. The bidder responding to this bid solicitation proposes to furnish all materials, labor, supplies, equipment and incidentals necessary to provide the equipment/materials/services described herein in accordance with the Notification of Solicitation (if applicable), Request for Information (if applicable), Request for Bid, Addenda, Contract, Bonds, Insurance, Plans, Specifications, any Instructions, Mandatory Requirements and Conditions.
22. Unless specified elsewhere in the document, all prices quoted must be F.O.B. County destination and will include all delivery, handling, and any other charges related to delivery including surcharges.
23. It will be understood that the bidder's sureties and insurers, as applicable, are subject to the approval of the County.
24. If a vendor is awarded a contract, Domestic (Kansas) corporations shall 1) furnish evidence of good standing in the form of a Certificate signed by the Kansas Secretary of State. Foreign (non-Kansas) corporations shall furnish evidence of authority to transact business in Kansas, in the form of a Certificate signed by the Kansas Secretary of State; and 2) a copy of the Corporation Resolution evidencing the authority to sign the Contract Documents, executed by the Corporation's Secretary or Assistant Secretary.
25. Sedgwick County will not award to any vendor that is currently listed in the exclusion records of the SAM (System for Award Management) website maintained by the General Services Administration (GSA) or to any vendor presently debarred, suspended, proposed for debarment, or declared ineligible for the award of contracts by any Federal agency.
26. Upon award, the bidder agrees to execute and deliver to the County a contract in accordance with the contract documents (if applicable) within ten days of notice of the award to the bidder. The bidder agrees that the surety/deposit given concurrently herewith will become the property of the County in the event the bidder fails to execute and deliver such contract within the specified time. In the further event of such failure, the bidder will be liable for the County's actual damages that exceed the amount of the surety.
27. It will be understood that time is of the essence in the bidder's performance. The bidder agrees that the County's damages would be difficult or impossible to predict in the event of a default in the performance hereof; and it is therefore agreed that if the bidder defaults in the performance of the contract documents, the bidder will be liable for payment of the sums stipulated in the contract documents as liquidated

damages, and not as a penalty.

28. The bidder hereby certifies that he or she has carefully examined all of the documents for the project, has carefully and thoroughly reviewed this Request for Bid, has inspected the location of the project (if applicable), and understands the nature and scope of the work to be done; and that this bid is based upon the terms, specifications, requirements, and conditions of the Request for Bid documents. The bidder further agrees that the performance time specified is a reasonable time, having carefully considered the nature and scope of the project as aforesaid.
29. It will be understood that any bid and any and/or all referencing information submitted in response to this Request for Bid will become the property of Sedgwick County, and will not be returned. As a governmental entity, Sedgwick County is subject to making records available for disclosure after Board of County Commission approval of the recommendation.
30. Sedgwick County will not be responsible for any expenses incurred by any vendor in the development of a response to this Request for Bid including any onsite (or otherwise) interviews and/or presentations, and/or supplemental information provided, submitted, or given to Sedgwick County and/or its representatives. Further, Sedgwick County will reserve the right to cancel the work described herein prior to issuance and acceptance of any contractual agreement/purchase order by the recommended vendor even if the Board of County Commissioners has formally accepted a recommendation.
31. By submission of a response, the bidder agrees that at the time of submittal, he or she: (1) has no interest (including financial benefit, commission, finder's fee, or any other remuneration) and will not acquire any interest, either direct or indirect, that would conflict in any manner or degree with the performance of bidder's services, or (2) benefit from an award resulting in a "Conflict of Interest". A "Conflict of Interest" will include holding or retaining membership, or employment, on a board, elected office, department, division or bureau, or committee sanctioned by and/or governed by the Sedgwick County Board of County Commissioners. Bidders will identify any interests, and the individuals involved, on separate paper with the response and will understand that the County, at the discretion of the Purchasing Director in consultation with the County Counselor, may reject their bid/quotation. The bidder certifies that this bid is submitted without collusion, fraud or misrepresentation as to other bidders, so that all bids for the project will result from free, open and competitive bidding among all vendors.
32. Sedgwick County will issue a purchase order/contract for the acquisition of products/services specified as a result of an award made in reference to this document. Contract documents will be subject to any regulations governed by the laws of the State of Kansas and any local resolutions specifically applicable to the purchase.
33. Any dispute arising out of the contract documents or their interpretation will be litigated only within the courts of the State of Kansas. No prepayment of any kind will be made prior to shipment. Payment will be made upon verification of delivery, compliance with specifications, assurance that the product/service performs as specified and warranted, and receipt of correct invoicing.
34. Sedgwick County will accept responses transmitted via a facsimile unless stated to the contrary within this document. Bids must be received prior to the time and dates listed to be considered responsive. Sedgwick County will not accept late responses and will return them to the sender. Further, Sedgwick County will NOT: (1) guarantee security of the document received; (2) be held responsible for Bids which are NOT legible (and may choose to reject such responses); and, (3) guarantee that the receiving facsimile machine will accept transmission or that phone lines are functioning and available for transmission. Submitting a bid response via facsimile does NOT relieve the bidder of: (1) responsibilities stated in the document (such as attendance at a mandatory pre-bid conference); (2) providing non-paper informational items which must be returned with the response (diskettes, large drawings, photographs, models, etc.); and, (3) providing original copies of bid sureties (bonds, certificates of insurance, etc.).

**REQUEST FOR BID**  
**#13-0049**  
**SLIP-IN PUMP AND TANK UNITS**

The undersigned, on behalf of the Bidder, certifies that: (1) this offer is made without previous understanding, agreement or connection with any person, firm, or corporation submitting a bid on the same project; (2) is in all respects fair and without collusion or fraud; (3) the person whose signature appears below is legally empowered to bind the firm in whose name the bid is entered; (4) they have read the complete Request for Bid and understands all provisions; (5) if accepted by the County, this bid is guaranteed as written and amended and will be implemented as stated; and (6) mistakes in writing of the submitted bid will be their responsibility.

NAME \_\_\_\_\_

DBA/SAME \_\_\_\_\_

CONTACT \_\_\_\_\_

ADDRESS \_\_\_\_\_ CITY/STATE \_\_\_\_\_ ZIP \_\_\_\_\_

PHONE \_\_\_\_\_ FAX \_\_\_\_\_ HOURS \_\_\_\_\_

TAX PAYER I.D. NUMBER \_\_\_\_\_ STATE INCORPORATED \_\_\_\_\_

COMPANY WEB SITE ADDRESS \_\_\_\_\_ E-MAIL \_\_\_\_\_

NUMBER OF LOCATIONS \_\_\_\_\_ NUMBER OF PERSONS EMPLOYED \_\_\_\_\_

TYPE OF ORGANIZATION: Public Corporation \_\_\_\_\_ Private Corporation \_\_\_\_\_ Sole Proprietorship \_\_\_\_\_  
 Partnership \_\_\_\_\_ Small Business \_\_\_\_\_ Manufacturer \_\_\_\_\_ Distributor \_\_\_\_\_ Retail \_\_\_\_\_ Dealer \_\_\_\_\_

General Nature of Business \_\_\_\_\_ FEIN/SS # \_\_\_\_\_ W-9 included \_\_\_\_\_

Not a Minority Owned Business \_\_\_\_\_ Minority Owned Business: \_\_\_ Certification # \_\_\_\_\_

African American \_\_\_ Asian \_\_\_ Hispanic \_\_\_ Native American \_\_\_ Other \_\_\_ Woman Owned Business \_\_\_\_\_

**ACKNOWLEDGE RECEIPT OF ADDENDA:** All addendum(s) are posted to our RFP/RFB web page and it is the vendor's responsibility to check and confirm all addendum(s) related to this document by going to <http://sedgwickcounty.org/finance/purchasing.asp>.

NO. \_\_\_\_\_, DATED \_\_\_\_\_; NO. \_\_\_\_\_, DATED \_\_\_\_\_; NO. \_\_\_\_\_, DATED \_\_\_\_\_

Qty	Description	Unit Cost	Extended Cost
2 ea.	Slip in pump and tank units	\$	\$
2 ea.	Option 1-to specifications	\$	\$
2 ea.	Option 2-to specifications		
2 ea.	Option 3-to specifications		
<b>Make/ Model</b>			
2 ea.	Maintenance manuals-Two complete sets Paper or CDROM	\$	\$
<b>Grand Total</b>		\$	\$
<b>Delivery Date:</b>			

In submitting a response to this document, vendor acknowledges acceptance of all sections of the entire document and has clearly delineated and detailed any exceptions.

Signature \_\_\_\_\_ Title \_\_\_\_\_

Print Name \_\_\_\_\_ Dated \_\_\_\_\_