



SEDGWICK COUNTY, KANSAS
DIVISION OF FINANCE
PURCHASING DEPARTMENT
525 N. Main, Suite 823 ~ Wichita, KS 67203
Phone: 316 660-7255 Fax: 316 383-7055

www.sedgwickcounty.org/finance/purchasing.asp

Addendum Number One
To The Drawings and Specifications for
WORK RELEASE RFB 14-0057

Issued: Wednesday, July 9, 2014

HANNEY & ASSOCIATES ARCHITECTS
1726 South Hillside, Wichita, Kansas

NOTICE TO BIDDERS

You are hereby instructed to include in your bids the following changes and/or corrections to the Drawings and Specifications for the **Sedgwick County Work Release Facility**.

The additions and/or corrections shall be considered as a part of the Contract Documents as if incorporated therein. Where the following corrections and/or additions vary from the conditions of the Drawings and Specifications, such following changes or additions shall govern.

I. GENERAL CLARIFICATIONS:

- 1.1 Please check the Sedgwick County website for a downloadable addendum information including any addendum-issued drawings and documents.
- 1.2 The bid date, time and location remain unchanged.
- 1.3 **INSIDE THE SECURE AREA.**
 - 1.3.1 Work one area per day.
For bidding purposes the General Contractor shall plan on working in only one area at a time. The Sheriff's department must escort each work detail, and they only have staff to cover one area at a time.
 - 1.3.2 Security Clearance:
Construction staff working inside the secure area must have passed a background check conducted by the Sheriff's department. Work outside the building and in the lobby does not require a security clearance.
 - 1.3.3 All staff working inside the security area must attend a 30-minute class. The class will be held on site. The General Contractor will coordinate the class attendance with the sub-contractors and the Sheriff's department.
- 1.4 **SUBSTITUTIONS:**
A substitution request was made for the Tennant DQS-5mm system with satin topcoat in lieu of the specified Stonhard GSI floor system. After reviewing the spec of the system requested, it was determined to not be an approved equal. The Tennant DQS system was found to be a broadcast specification and our specification calls for troweled.