



SEDGWICK COUNTY, KANSAS
DIVISION OF FINANCE
PURCHASING DEPARTMENT

525 N. Main, Suite 823 ~ Wichita, KS 67203
Phone: 316 660-7255 Fax: 316 383-7055

www.sedgwickcountv.org/purchasing

REQUEST FOR BID
#14-0080
TB RAMP AND STAIRS

ADDENDUM #2

August 19, 2014

The following information is in regard to **RFB 14-0080**.

Please see the attached documents regarding the above mentioned project.

Vendors are responsible for checking the web site and **acknowledging any addenda on the proposal response form**.

Kimberly Evans
Purchasing Agent



Sedgwick County...
working for you

Facility Project Services

510 N. Main, Suite 602, Wichita, KS 67203 - www.sedgwickcounty.org - TEL: 316-660-9865 - FAX: 316-383-7696

August 19, 2014

Kim Evans
Sedgwick County Purchasing
525 N Main, Ste. 823
Wichita, KS 67203

Dear Kim:

Please find below the answers to questions received for Sedgwick County project 14-0080, TB Entrance Ramp and Stairs.


- Q1. If this entrance is to be ADA accessible, dose the door need to have an automatic opener installed on it?**
A1. *No, an automatic door opener is not required for an ADA compliant entrance.*
- Q2. Reference revised plan sheet SP2.0. There appears to be a conflict with the new ramped sidewalk and the new rain leader drain line. Is the elevation of the new ramped sidewalk too low for the new rain leader drain line to cross underneath it as shown?**
A2. *There is an elevation conflict between the drain line and sidewalk, see attached cut sheet for new route of rain leader drain line.*

Sincerely,

Robert J. Lawrence
Senior Construction Project Manager
Facility Project Services


attach:

1. Rain leader cut sheet



EXISTING
DOWNSPOUT

CONNECT NEW 4" PVC DRAIN PIPE FROM EXISTING DOWNSPOUT CONNECTOR TO NEW CURB OPENING. PIPE SHALL BE INSTALLED W/ A MIN. 0.5% SLOPE TO CURB. REMOVE AND RE-INSTALL PORTION OF CURB AS REQUIRED TO INSTALL CURB OPENING PER MANUFACTUREERS DIRECTIONS. CURB OPENING SHALL BE A NEENAH FOUNDRY R-3262 SERIES STORM WATER OPENING W/ 4" PIPE CONNECTOR.



GLMV Architecture

1525 E. Douglas
Wichita, KS 67211
Tel: (316) 266-9287
Fax: (316) 265-6646
www.glmv.com



SHEET TITLE: ADDENDUM #2 -
REVISIONS TO RAINLEADER

PROJECT: SEDGWICK COUNTY HEALTH DEPT.
-TB ENTRANCE RAMP AND STAIRS

PROJ. NO.: 12151.000

DATE: 08.18.14

1 OF 1

Contractor List**RFP: 14-0080**

Page 1 of 1

Generated 8/19/2014 2:31:38 PM

Company	Type	Contact	Address	Phone	Fax	Email	Date (CST)
Design One Contractors, llc	Prime	Paul Sponzel	500 N West St Garden Plain, KS 67050	(316) 393-8130		rsponzel@cox.net	8/11/2014 10:00 AM
K.C.N.R., LLC	Plan Room	Jennifer Loveland	230 Laura Wichita, KS 67211	(316) 263-0265		Jloveland@kcnr.kscoxmail.com	8/11/2014 10:07 AM
kansas paving	Prime	greg elpers	4880 n broadway wichita, KS 67204	(316) 832-0828		elpers@kansaspaving.com	8/11/2014 10:48 AM
Bauer & Son Construction Co., Inc.	Prime	Steve Houser	415 S. Zelta Wichita, KS 67207	(316) 683-1492 Ext. 3	(316) 684-1372	shouser@bscconstruction.com	8/11/2014 10:56 AM
Caro Construction Co., Inc.	Prime	Warren Way	527 N. Walnut Wichita, KS 67208	(316) 267-7505		david@caroconstruction.com	8/12/2014 3:14 PM
Van Asdale Construction	Prime	Jeff Van Asdale	353 N. Pennsylvania Wichita, KS 67214	(316) 264-0222		vanasdaleconst@sbcglobal.net	8/13/2014 11:21 AM
The Builders Association	Plan Room	Lea Anne Hutton	720 Oak Street Kansas City, MO 64106	(816) 595-4116	(816) 285-0575	lhutton@buildersassociation.com	8/13/2014 2:47 PM
Penner Construction Services, Inc.	Prime	Nick Penner	PO Box 771261 Wichita, KS 67205	(316) 706-8085		nickp@pennerconstructionservices.com	8/17/2014 4:51 PM
Bauer & Son Construction Co., Inc.	Prime	Steve Houser	415 S. Zelta Wichita, KS 67207	(316) 683-1492 Ext. 3	(316) 683-1372	shouser@bscconstruction.com	8/18/2014 9:51 AM
graycon building group	Prime	brad	1861 n rock road wichita, KS 67212	(316) 978-9047		brad@grayconbg.com	8/18/2014 11:57 AM