



**SEDGWICK COUNTY, KANSAS**  
***DIVISION OF FINANCE***  
**Purchasing Department**  
**Joseph Thomas, Purchasing Director**

525 N. Main, Suite 823 ~ Wichita, KS 67203  
Phone: 316 660-7255 Fax: 316 383-7055  
<https://ssc.sedgwickcounty.org/RFORFPWebApp/RFP2.aspx>

**REQUEST FOR BID**  
**#14-0094**  
**EMS POST 10 EMERGENCY GENERATOR**  
**ADDENDUM #1**

October 22, 2014

The following is to ensure that vendors have complete information prior to submitting a bid. Here are some clarifications regarding the bid for EMS Post 10 Emergency Generator.


Question and/or statements of clarification are in **bold font**, answers to specific questions are italicized.

**Q1) I believe that the city of Wichita requires all generators to be rated to handle the main breaker that it is serving. Is there going to be an exception allowed for this project?**

*A1) Refer to sheet E22.1 Service Entrance and Distribution Riser Diagram*

- 1. Breaker on generator shall be 300/2 in lieu of 400/2 as indicated*
- 2. Existing Main Switch 400/2 shall be fused at 300 Amps.*
- 3. Feeders to remain as indicated.*

Firms interested in submitting a proposal, must respond with complete information and all supplementary materials and **deliver on or before 1:45 p.m. (CDT), Tuesday, October 28, 2014**. Late proposals will not be accepted and will not receive consideration for final award.

  
\_\_\_\_\_  
Kimberly Evans  
Purchasing Agent