



SEDGWICK COUNTY, KANSAS
DIVISION OF FINANCE
Purchasing Department
Joseph Thomas, Purchasing Director
525 N. Main, Suite 823 ~ Wichita, KS 67203
Phone: 316 660-7255 Fax: 316 383-7055
<http://sedgwickcounty.org/finance/purchasing.asp>

ADDENDUM 3
16-0040
HVAC CONTROL SYSTEM

April 15, 2016

The following is to ensure that vendors have complete information prior to submitting a bid. Here are some clarifications regarding the bid for the HVAC Control System.

Questions are in **bold**, answers are in *italics*.

- 1. The VAV actuators at the 271 W. 3rd building are enclosed in each VAV box. These are simple and inexpensive to repair but will add a lot of cost to retrofit all of them to a newer style damper and actuator. The bid specification says to include actuators for each VAV box. Please verify that these are to be included in the base bid.**

Existing VAV box actuators are only necessary to replace if found to not be compatible with new DDC system. During system installation, verification of VAV box actuator operation will be tested by successful bidder and any failures will be presented to Sedgwick County in written form for evaluation.

Include in bid price per VAV box:

- Actuator*
- Newer style of damper*
- Associated labor and cost for a complete retrofit if deemed necessary.*

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID RESPONSE PAGE.

Kimberly Evans
Purchasing Agent
Kimberly.J.Evans@sedgwick.gov