

**PURCHASING RECOMMENDATION SEPTEMBER 8, 2014**

**SLIP-IN PUMP & TANK UNIT -- FIRE DISTRICT 1  
FUNDING -- FIRE DIST. ADMIN**

(Request sent to 22 vendors)

RFB #14-0074 S/C 8000044701

	Hays Fire & Rescue Sales & Service, LLC	Chief Fire & Safety Company, Inc.	Max Fire Apparatus, Inc.
Slip-in Pump & Tank Unit	\$17,202.00	\$19,323.00	\$17,180.38
Option 1	\$4,000.00	\$4,357.00	\$3,492.00
Grand total	\$21,202.00	\$23,680.00	\$20,672.38
Delivery date	12/1/2014	12/1/2014	60 days ARO
Acknowledge addendum	Yes	Yes	Yes
	Watts Manufacturing	Chloeta Fire, LLC dba Chloeta Manufacturing	<b>Emergency Fire Equipment, Inc.</b>
Slip-in Pump & Tank Unit	\$17,300.00	\$22,869.10	<b>\$16,477.00</b>
Option 1	\$2,500.00	\$5,596.95	<b>\$4,210.00</b>
Grand total	\$19,800.00	\$28,466.05	<b>\$20,687.00</b>
Delivery date	11/3/2014	12/1/2014	<b>12/1/24</b>
Acknowledge addendum	Yes	Yes	<b>Yes</b>
No Bid	Precision Fire Apparatus	Garsite, LLC	FYR-TEK, Inc.
	Sentinel Emergency Solutions, LLC		

**Recommend the lowest and best bid from Emergency Fire Equipment, Inc. in the amount of \$20,687.00.**

Watts Manufacturing did not meet the pump panel and tank-fill valve requirements. Max Fire Apparatus, Inc. did meet specifications but warranty issues, although rare, could require skid to be returned to Castle Rock, Colorado for service, a distance of 500 miles. Emergency Fire Equipment is located in Mayfield, Kansas, a distance of 45 miles for any warranty service.

This is a replacement Slip-In Pump & Tank Unit for Sedgwick County Fire District #1, surplus will be sold on Purplewave.