ADDENDUM NUMBER TWO

To The Drawings and Specifications for Sedgwick County Courthouse Cooling Tower Replacement

Issued: May 4, 2023

HANNEY & ASSOCIATES ARCHITECTS

1726 South Hillside, Wichita, Kansas

NOTICE TO BIDDERS

You are hereby instructed to include in your bids the following changes and/or corrections to the Drawings and Specifications for the **Sedgwick County Courthouse** – **Cooling Tower Replacement**, at 525 North Main in Wichita, Kansas.

The additions and/or corrections shall be considered as a part of the Contract Documents as if incorporated therein. Where the following corrections and/or additions vary from the conditions of the Drawings and Specifications, such following changes or additions shall govern.

I. GENERAL CLARIFICATIONS:

- 1.1 The Bid Date and Time shall remain unchanged.
- 1.2 The Contract Documents are modified as noted in this Addendum and all conditions not modified herein remain unchanged.
- 1.3 Specifications.

The project specifications have been posted to the Counties web site and are part of the contract documents. Please make sure to download the Specifications along with the drawings.

1.4 Prime Contractor.

The Mechanical Contractor can bid this project as the Prime Contractor, provided the bidder meets the specified requirements, including but not limited to bonding and insurance.

- 1.5 Pumps require inertia pads with isolators and fully grouted pump bases as per manufacturer recommendations. Refer to Pump Schedule Sheet MP-1.0 and specifications for additional information.
- 1.6 PVC condenser water piping not allowed.

ADDENDUM TWO Page 1 of 2

II. MECHANICAL SPECIFICATIONS:

- 2.1 Section 23-65-00 Cooling Towers:236500.2.1: Add Delta Cooling Towers, Inc. as an approved manufacturer for the cooling towers.
- Section 23-25-00 HVAC Water Treatment:
 232500.2.1: Chemtreat shall be listed as the only approved manufacturer for HVAC Water Treatment. Omit Kan-Tech, Inc. from specification.
- 2.3 Section 23-21-23 Hydronic Pumps:232500.2.5: Add TACO as an approved manufacturer for Hydronic Pumps.

III. MECHANICAL DRAWINGS:

- 3.1 Sheet M1.1
 - a. Plan Note 20 Shall Read:
 Calibrated Balance Valve. Set Each Tower Sweeper For Equal Flow Rates 133
 GPM.
 - b. Plan Note 21 Shall Read:
 Provide Field Fabricated Unistrut Free Standing Frame. Refer To Electrical Detail.

END OF ADDENDUM TWO

ADDENDUM TWO Page 2 of 2